



Product certificate K97825/02

Issued 2021-01-01

Replaces K97825/01

Page 1 of 2

Drinking water system components – health effects according to NSF/ANSI/CAN 61

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the product:

EPDM seals

supplied by

Secil Kaucuk San.ve Tic.A.S.

as specified in this product certificate and marked with the Kiwa NSF/ANSI/CAN 61 in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline Manual K15007 for “drinking water system components – health effects according to NSF/ANSI/CAN 61”, dated 01 November 2020.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

289170315

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
Secil Kaucuk San.ve Tic.A.S.
Tarsus-Adaa Karayolu 7 Km.
33400 Tarsus-Mersin
Turkey
Tel. 324 616 1140
www.seciltr.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Drinking water system components – health effects according to NSF/ANSI/CAN 61

Product specification

The product mentioned below belongs to this certificate.

Product	Nominal Hardness [IRHD]	Size	Water Contact Temp	Water Contact Material
EPDM seals EPDM C85 PW [1]	48	[2]	cold water [3]	EPDM

[1] Joining and sealing materials
 [2] Certified for a nominal dimensions 200 – 4000 mm
 [3] Cold water application: for intended use in continuous exposure to water at ambient temperature. Products are tested for an end-use temperature of 23 ± 2 OC (73 ± 4 OF).

Hygienic aspects

Approval:

This product is approved on the basis of the requirements set in NSF/ANSI/CAN 61.

Kiwa NSF/ANSI/CAN 61 criteria:

The product certification is based on two main criteria. The product shall permanently comply with:

- the product recipe approved during the assessment procedure. The recipe is laid down for the confidentiality reasons undisclosed in the appendix to certificate K97825. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- specific product requirements for the hygienic aspects, laid down in the appendix to certificate K97825. For confidentiality reasons this appendix is not public.

Marking

The product shall be marked with



Or words **KIWA NSF/ANSI 61**

Location of the mark:

- If the dimensions of the products are such that the indications applied to them may impair the product, the products may be marked per package in consultation with the manufacturer, the buyer and Kiwa. Products produced by cutting or die cutting out of sheets may be marked per package.

Mandatory marks:

- “Manufacturers name or logo”
- “Product identification (trade name or product type)”
- “Production code”
- “Certificate number”

The realization of the marks as is follows: clearly and indelible.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Secil Kaucuk San.ve Tic.A.S

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier’s processing guidelines for the proper storage and transport methods.